SELECTLOK®
A McNaughtans Company

TEST REPORT

Document No#: LOK2611_v01
Document Date: 13/11/2026

Test Report

DECLARATIONS OF CONFORMITY (REACH & RoHS)
Earth Neutral Bars and Insulators

Sample Name:	Brass E/N Bars and Insulators
Report Job No#:	LOK2611
Declaration Periods:	01/09/2024 ~ 01/09/2025
Test Item(s):	REACH Directive 1907/2006 RoHS EU Directive 2002/95/EG (Jan.27.2003) RoHS Directive 2011/65/EU Conflict Region: 3TG Free
Approved by:	LOK Technical Product Manager LOK QC Manager

Results Summary:
The following results(s) were submitted and identified on behalf of Selectlok as;

Testing Laboratory (Signatories):

Seal	Date	Manufacturer/Suppliers Approved Signatory
QUALITY PRODUCTS SELECTLOK A MCNAUGHTANS COMPANY ★★★★★	13/11/2026	KEVAL PATEL (Managing Director)

Disclaimer: The above document is derived from original test reports and certificates carried out by the manufacturer and/or independent lab facilities. The contents of this report are meant for information purposes only relating to product & material quality, industry standards and/or guidelines. The contents of this report should not be used for advertisement, evidence or litigation purposes.

NB: The information contained within this document accurate as of the time of publication and is subject to change, Selectlok reserves the right to alter designs, dimensions & technical information without notice. **©2026 McNaughtans Pty Ltd t/a Selectlok | Page 1 of 4**

REACH Compliance Declaration.

We, “McNaughtans PTY LTD t/a Selectlok”, here within Confirm that continuing as of 01/09/25 none of the products which “Selectlok Australia” obtains from our suppliers and manufacturers, Contains the substances indicated in:

- RoHS Directive 2011/65/EU
- REACH Directive 1907/2006
- The European Parliament and of the Council.

We confirm that we will keep the engagement in conformity with Article 33 of REACH Regulation.

REACH compliant means that all relevant substances and articles are excluded from the regulation.

McNaughtans PTY LTD t/a Selectlok.

SELECTLOK®
A McNaughtans Company

NB: The information contained within this document accurate as of the time of publication and is subject to change, Selectlok reserves the right to alter designs, dimensions & technical information without notice. **©2026 McNaughtans Pty Ltd t/a Selectlok | Page 2 of 4**

SELECTLOK®
A McNaughtans Company

TEST REPORT

Document No#: LOK2611_v01
Document Date: 13/11/2026

Conflict Minerals.

We, “McNaughtans PTY LTD t/a Selectlok”, here within Confirm and Declare that continuing as of 01/09/25 Raw Materials used for Production of our items do not come from the geographical area defined as “Conflict Region”.

- We confirm that all the Products we source are 3TG Free

McNaughtans PTY LTD t/a Selectlok.

SELECTLOK®
A McNaughtans Company

NB: The information contained within this document accurate as of the time of publication and is subject to change, Selectlok reserves the right to alter designs, dimensions & technical information without notice. **©2026 McNaughtans Pty Ltd t/a Selectlok | Page 3 of 4**

SELECTLOK®
A McNaughtans Company

TEST REPORT

Document No#: LOK2611_v01
Document Date: 13/11/2026

RoHS Compliance Declaration.

We, “McNaughtans PTY LTD t/a Selectlok”, here within Confirm that continuing as of 01/09/24 products under the scope of BRASS EARTH/NEUTRAL BARS. Which we source and/or have produced from our manufacturing and supplier partners, meet the following characteristics and are in compliance with ROHS norms as per:

- RoHS EU Directive 2002/95/EG (Jan.27.2003)

Materials: Brass (Free Cutting) | CuZn39Pb3
Coating: Natural

McNaughtans PTY LTD t/a Selectlok.

SELECTLOK®
A McNaughtans Company

CHEMICAL COMPOSITION FOR SAMPLE OF BRASS TERMINAL BAR		VALUE
1. ZINC	(Zn)%	38.82
2. LEAD	(Pb)%	3.13
3. TIN	(Sn)%	0.323
4. PHOSOHOROUS	(P)%	0.00510
5. MANJANESE	(Mn)%	0.00880
6. IRON	(Fe)%	0.295
7. NICKLE	(Ni)%	0.340
8. SILICON	(Si)%	0.0260
9. MAGNESIUM	(Mg)%	0.00120
10. CHROMIUM	(Cr)%	0.00470
11. ARSENIC	(As)%	0.0180
12. ANTIMONY	(Sb)%	0.0170
13. BISMUTH	(Bi)%	0.00340
14. COBALT	(Co)%	< 0.0015
15. ALUMINUM	(Al)%	0.0110
16. SULFUR	(S)%	0.00130
17. COPPER	(Cu)%	56.90

Note: This report relates only to the particular sample tested from order batch. Any correction not attested shall invalidate this report

** END OF REPORT **

NB: The information contained within this document accurate as of the time of publication and is subject to change, Selectlok reserves the right to alter designs, dimensions & technical information without notice. **©2026 McNaughtans Pty Ltd t/a Selectlok | Page 4 of 4**